

Rev. 2-12 State Form 37777

INSPECTOR'S LOG OF PRECAST, PRESTRESSED CONCRETE MEMBERS

Div. of Construction

File

BEAM CONTRACTOR

Prestress Services Industries - Lexington, KY

CONTRACTOR NO.

8502

CONTRACT NO.

IR-34937: Salem Rd. over S.R. 265

JOB NO.

L2302

PROJECT NO.

0900254

DESIGNATION NO.

0900254

BRIDGE FILE NO.

265-10-9604

TYPE 54" Bulb Tee SIZE 54" H x 48" W TOTAL NUMBER 12

BEAM		DATE	DATE	CONCRETE		DETENSIONING		DATE	SHIPPING		BEAM CAMBER		Rebar	Alignment	Appearance	Acceptance	Yellow Card		Date
Number		Tensioned	Poured	Data		Cylinder Test		Detensioned	Cylinder Tests		Initial	Shipping	Check	Check	Check	Check			Shipped
				Slump	Air	Date	PSI		Date	PSI	Inches	Inches					Date	No.	
501	-1	12/26/12	12/27/12	7 3/4	5.6%	12/28/12	6,967	12/28/12	01/18/13	9,655	1 3/4	Will check when shipped	OK	OK	OK	needs sealed @ jobsite	Will be sent when shipped	47350221	Due to ship March 2013
				7 3/4	5.1%		7,533			9,019									
				7 3/4	5.1%		7,233			7,887									
502	-2	12/26/12	12/27/12	7 3/4	5.1%	12/28/12	7,233	12/28/12	01/18/13	7,887	1 1/2	Will check when shipped	OK	OK	OK	needs sealed @ jobsite	Will be sent when shipped	47350222	Due to ship March 2013
				7 3/4	5.0%		7,569			8,488									
				7 3/4	5.0%		6,720			8,329									
505	-3	12/26/12	12/27/12	7 3/4	5.0%	12/28/12	6,720	12/28/12	01/18/13	8,329	1 1/2	Will check when shipped	OK	OK	OK	needs sealed @ jobsite	Will be sent when shipped	47350223	Due to ship March 2013
				7 1/4	5.8%		7,091			8,064									
				7 3/4	5.7%		7,303			8,966									
506	-4	12/28/12	12/28/12	7 3/4	6.8%	12/28/12	6,679	12/28/12	01/18/13	8,806	2	Will check when shipped	OK	OK	OK	needs sealed @ jobsite	Will be sent when shipped	47350224	Due to ship March 2013
				8	5.8%		6,790			8,753									
				7 3/4	5.4%		7,109			8,771									
502	-5	12/28/12	12/28/12	7 3/4	5.4%	12/28/12	7,109	12/28/12	01/18/13	8,771	1 3/4	Will check when shipped	OK	OK	OK	needs sealed @ jobsite	Will be sent when shipped	47350225	Due to ship March 2013
				7 3/4	5.1%		6,790			8,655									
				7 3/4	5.2%		7,179			8,789									
505	-6	12/28/12	12/28/12	7 3/4	5.2%	12/28/12	7,179	12/28/12	01/18/13	8,789	1 3/4	Will check when shipped	OK	OK	OK	needs sealed @ jobsite	Will be sent when shipped	47350226	Due to ship March 2013
				7 3/4	5.0%		7,303			8,630									
				7 3/4	5.2%		7,321			8,753									
503	-7	01/02/13	01/02/13	7 3/4	5.7%	01/02/13	6,702	01/02/13	01/18/13	8,718	1 5/8	Will check when shipped	OK	OK	OK	needs sealed @ jobsite	Will be sent when shipped	47350227	Due to ship March 2013
				7 1/2	5.7%		6,790			8,718									
				7 1/2	5.0%		7,409			8,718									
502	-8	01/02/13	01/02/13	7 1/2	5.0%	01/02/13	7,409	01/02/13	01/18/13	8,718	1 1/2	Will check when shipped	OK	OK	OK	needs sealed @ jobsite	Will be sent when shipped	47350228	Due to ship March 2013
				7 1/2	5.0%		7,286			8,700									
				7 1/2	5.2%		7,339			8,488									
505	-9	01/02/13	01/02/13	7 1/2	5.2%	01/02/13	7,339	01/02/13	01/18/13	8,488	1 3/4	Will check when shipped	OK	OK	OK	needs sealed @ jobsite	Will be sent when shipped	47350229	Due to ship March 2013
				7 1/2	5.0%		7,356			8,630									
				7 1/2	5.1%		7,445			8,630									
504	-10	01/03/13	01/03/13	8	6.7%	01/03/13	6,967	01/03/13	01/18/13	7,834	1 7/8	Will check when shipped	OK	OK	OK	needs sealed @ jobsite	Will be sent when shipped	47350230	Due to ship March 2013
				8	6.6%		6,861			8,170									
				7 1/2	5.0%		7,109			9,072									

Copy

Comments:

Planned Erection Camber is 3.657 inches for all beams.

Div

File

Department Signature